| Name: | Vent-Axia | Vent-Axia | Vent-Axia | Vent-Axia | Vent-Axia | Vent-Axia | Vent-Axia | Vent-Axia |
|---|---|---|---|---|---|---|---|---|
| Model ID (Stock Ref.) : | SLP100EC | SLP125EC | SLP150EC | SLP200EC | SLP250EC | SLP315EC | SLP400EC | SLP500EC |
| Declared as: RVU or NRVU/UVU or BVU | NRVU/UVU | NRVU/UVU | NRVU/UVU | NRVU/UVU | NRVU/UVU | NRVU/UVU | NRVU/UVU | NRVU/UVU |
| Speed Drive | Variable Speed | Variable Speed | Variable Speed | Variable Speed | Variable Speed | Variable Speed | Variable Speed | Variable Speed |
| Type HRS (Recuperative, Regenerative, None) | None | None | None | None | None | None | None | None |
| Thermal Eff: [ (%), NA(if none)] | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Nominal Flow Rate (m3/s) | 0.05 | 0.07 | 0.08 | 0.12 | 0.13 | 0.24 | 0.37 | 0.75 |
| Efective Elec. Power Input (kW): (@Nom.Flow Rate&Ext. Pressure) | 0.05 | 0.06 | 0.06 | 0.09 | 0.08 | 0.09 | 0.25 | 0.55 |
| SFPint [W/(m3/s)] | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Face Velocity (m/s) @ Design Flow Rate | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Nominal External Pressure: ($\Delta p_{s,\ ext}$) in Pa | 247 | 250 | 250 | 230 | 204 | 150 | 300 | 350 |
| Internal Pressure Drop of Ventilation Components ($\Delta p_{s,int}$) in Pa; | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Additonal Internal Press. Drop of Non-Ventilation Comp.: $\mathbf{\Delta p_{s,add}}$ (Pa) | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Static Eff. of fans used in accordance with Regulation (EU) No 327/2011; | TBC | TBC | TBC | TBC | TBC | TBC | TBC | TBC |
| Declared: -Max Internal & External Leakage Rates(%) for BVUs or carry over (for regenerative heat exchangers only), -&Ext. Leakage Rates (%) for Ducted UVUs; | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Energy Performance, preferably energy classification, of the Filters (declared information about the calculated AEC) | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Position and description of visual filter warning for RVUs intended for use with filters, including text pointing out the importance of regular filter changes for performance and energy efficiency of the unit | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| For UVUs (Instructions Install Grilles Façade) | In F&W | In F&W | In F&W | In F&W | In F&W | In F&W | In F&W | In F&W |
| Internet Address (for Disassembly Instructions) | www.vent-axia.com | www.vent-axia.com | www.vent-axia.com | www.vent-axia.com | www.vent-axia.com | www.vent-axia.com | www.vent-axia.com | www.vent-axia.com |