Name:	Vent-Axia
Model ID (Stock Ref.) :	MVDC - 181520D
SEC Class	E
SEC Value ('Average')	-14.85
SEC Value ('Warm')	-5.45
SEC Value ('Cold')	-31.25
Label Required? (Yes/No=Out of scope)	Yes
Declared as: RVU or NRVU/UVU or BVU	RVU/UVU
Speed Drive	Multi-Speed
Type HRS (Recuperative, Regenerative, None)	None
Thermal Eff: [(%), NA(if none)]	N/A
Max. Flow Rate (m3/h)	388.80
Max. Power Input (W): (@Max.Flow Rate)	44.00
LWA: Sound Power Level (dB)	54.23
Ref. Flow Rate (m3/s)	0.07560
Ref. Pressure Diff. (Pa)	250.00
SPI [W/(m3/h)]	0.07
Control Factor & Control Typology: (CTRL/ Typology)	
Control Factor; CTRL	1.00
Control Typology	Manual Control
Declared: -Max Internal & External Leakage Rates(%) for BVUs or carry	<5% Internal, <5% External
over (for regenerative heat exchangers only),	
-&Ext. Leakage Rates (%) for Ducted UVUs;	
Mixing Rate of Non-Ducted BVUs not intended to be equipped with	N/A
one duct connection on either supply or extract air side;	
Position and description of visual filter warning for RVUs intended for	N/A
use with filters, including text pointing out the importance of regular	
filter changes for performance and energy efficiency of the unit	
For UVUs (Instructions Install Regulated Supply/Extract Grilles Façade)	In F&W
Internet Address (for Disassembly Instructions)	www.vent-axia.com
Sensitivity p. Variation@+20/-20 Pa: (for Non-Ducted VUs)	N/A
Air Tightness-ID/OD-(m3/h) (for Non-Ducted VUs)	N/A
Annual Electricity Consumption: AEC (kWh/a)	0.92
Annual Heating Saved: AHS (kWh/a)	
AHS: Average	17.15
AHS: Warm	7.76
AHS: Cold	33.55